West Pierpont Ave. near 300 West and 200 south just north of Pioneer Park in Salt Lake City Utah was an excellent site choice for a multi resident housing complex with ground floor retail space. This area not only has nearby amenities but receives large amounts of direct winter daylight.

A main concept was to have high density and large amounts of daylight penetration into each unit. As found in previous design exercises by running windows across the unit's lengthwise daylight penetration could be increased. However this came at a cost of having low density as more footprint was needed to have good amounts of direct daylight. By opening one wall completely with floor to ceiling glass large amounts of daylight penetrates into the space even in walls that have a shorter length. The units are then oriented with the units facing East South and West with the majority of units on the south façade.


This creates an ideal opportunity to use concrete floors as a thermal mass for passive heat gain. Covered privacy balconies provide protection from the summer sun. But operational louvers help to protect from sun throughout other summer months, control glare, and at night can be closed to provide an extra thermal and wind barrier. It is critical that Schöck Isokorb® type S. for steel structures are used. Having a continuous tube steel structure penetrate the wall assembly would cause MASSIVE heat loss due to thermal bridging. While private balconies and interior floors are tile on concrete for passive thermal properties, walkways are tile on XPS to create a structural acoustical barrier.


The green roof acts as a regulating thermal mass keeping the roof cool during hot summer days and acting as insulation during winter months and provides opportunity for a storm water collection system.

Using Equest it became apparent that due to the high amount of glass, energy efficient glass was critical. Because covered balconies are an integral part of the initial design they are included in the Baseline run. After playing with several energy efficiency measurements it was found that by combining triple pain low e glass, as well as thicker roof and exterior wall insulation the heating costs dropped by nearly half. The most substantial change from the three energy saving measures was from the change in glass type.

Pre-Fabricated units are shipped to site Then stacked each unit acts as a space frame truss each shared wall only has contact structurally with other units at the corners. Each floor is separate from adjacent ceiling this system helps create acoustical barriers and helps prevent thermal bridging through structure. Sound is also impeded by use of resilient bars, and other barriers like closets plumbing walls and batt insulation. Large holes cannot be made in tube steel frame: stacks, plumbing, electrical and gas are brought up through a C-channel Gyp. wall. Tank-less water heaters are placed under sinks. Small individual air heating and cooling units are used in each room.


Due to the split nature of the building, for vertical transport it I suggest 2 cars @ 2000 lb. Capacity 200 fpm the primary reason to use two low end lift systems instead of one high end cart is because the building is disconnected and needs vertical transport in two opposite corners.





Pre-Fabricated units are shipped to site Then stacked each unit acts as a space frame truss each shared wall only has contact structurally with other units at the corners. Each floor is separate from adjacent ceiling this system helps create acoustical barriers and helps prevent thermal bridging through structure





Winter





Summer




Winter Solstace

Daylight Only Light Source







No Thermal Bridge




Floor to Ceiling Glass Allows For Lots of Direct Daylight


A main concept was to have high density and large amounts of daylight penetration into each unit. As found in previous design exercises by running windows across the unit's lengthwise daylight penetration could be increased. However this came at a cost of having low density as more footprint was needed to have good amounts of direct daylight. By opening one wall completely with floor to ceiling glass large amounts of daylight penetrates into the space even in walls that have a shorter length. The units are then oriented with the units facing East South and West with the majority of units on the south façade.









. Large holes cannot be made in tube steel frame: stacks, plumbing, electrical and gas are brought up through a C-channel Gyp. wall. Tank-less water heaters are placed under sinks. Small individual Air heating and cooling units are used in each room.












The green roof acts as a regulating thermal mass keeping the roof cool during hot summer days and acting as insulation during winter months and provides opportunity for a storm water collection system.








Site Analysis

Group Work Main Contributor : Joseph Briggs

SITE ANALYSIS





SITE ONE

- Owner: Greek Orthodox Church of Salt Lake \$895.200 Value:
 - Acres: 1.16
- \$/SF: \$18
- Soil: Alluvial Fan and Debris Fan Deposits D-3 Zoning:

SITE TWO

- Owner: Tire Town Phase I, LLC
- \$357.500 Value:
- Acres: 0.39
- \$/SF: \$21
- Soil: Alluvial Fan and Debris Fan Deposits D-3 Zoning:
- Local Asset O Bus Stop TRAX Route Bus Route Silt & Clay Alluvium Alluvial Fan & Debris Fan

Scale: 1"=100"

Part of Closest Grocery Store: Harmons | 135 E 100 S | 0.85 miles away Washington Elementary School | 420 N 200 W | 1.25 miles away Bryant Middle School | 40 S 800 E | 2.15 miles away West High School | 241 N 300 W | 0.75 miles away

SHADOW STUDIES





Vernal Equinox 同历

Autumnal Equinox

0

Ľ.


Summer Solstice







ENVIRONMENTAL










June

Sun Shading Chart











1 T



January

February

March

April

May

August

September

December


October

November





July



Facade Studies Focusing on Shadow

8 2-West Middle Study



Suggested Car 2 Cars@ 2000 lb Capacity 200 fpm Recommended for 75-125' Buildings

Ballast 125 units total Green Roof											
		18		25							
		17	~))							
	8		11								
26	8		13	57							
	7		9	JT							
	5		11								
	8		10								
	n/a		n/a	Retail							


Micro Unit 1 person avg 1 Bed 2 person avg 2 Bed 3 person avg

Moderate-rental housing 2.0 avg per bedroom

125 units @ 2ppl/unit 250 Residents Percent Handling Capacity Moderate-rental housing 8%/5min Due to Work/School Rush Recommended Wait Time 36–48 sec Handling Capacity 20ppl/5min

Lobby+7floors+Roof=9 Floors = 95' Normal load 10persons @ 2000 fpm 10 ft floor to floor avg = approx 70 sec/trip 140 sec round trip = approx 21ppl/5min Wait time 60% of Interval 1 Elev. has PHC needed butunacceptable wait time of 84 sec.Due to Split/Gate in Building 2 Elev Required2 Elev. has two times PHC neededand sufficiant wait time of 42 sec.

Circulation & Vertical Transportation



3 3-Retai

Appendix a. studio drawings with very little climate and tech. control systems intigration

Drawing 1 of 1 Figure Ground Modular to Site Concept





FIGURE GROUND

Appendix b.1 A brief Equest printout that shows some analysis using Equest.


Page 1 of 2 3D Geometry

Using Equest it became apparent that due to the high amount of glass, energy efficient glass was critical. Because covered balconies are an integral part of the initial design they are included in the Baseline run. After playing with several energy efficiency measurements it was found that by combining triple pain low e glass, as well as thicker roof and exterior wall insulation the heating costs dropped by nearly half. The most substantial change from the three energy saving measures was from the change in glass type.




Appendix b.2

Page 2 of 2 **EEM Summary Reports**



Ventilation Fans



Space Cooling

Run Date/Time: 04/03/14 @ 23:10

Misc. Equipment

Electric Consumption (kWh x000)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	0.00	0.09	0.18	0.54	5.88	14.79	31.32	26.52	7.85	1.98	0.07	-	90.21
Hoat Reject.				1		-			-		1.00	~	-
Refrigeration	-	-	~	-		~	~	-	-	*		-	-
Space Heat	τ	-	8	-		1	1	~	1.1	~		-	-
HP Supp.	31	-			-	1.6	÷.	-	-	4		-	-
Hot Water	10.61	10.06	11.24	10.69	9.81	8.38	7.69	7.08	6.79	7.54	8.05	9,71	107.64
Vent. Fans	6.78	5.89	6.32	6.05	7.21	7.74	9.26	8.92	6.96	6.41	6.30	6.58	84.41
Pumps & Aux.	0.11	0.09	D.08	0.06	0.02	0.01		-	0.02	0.05	0.09	0.11	D.65
Ext. Usage	8.35	6,60	7.31	7.07	5.41	5.24	5.41	8.00	7.74	8.00	8.08	8.35	85.55
Misc. Equip.	12.71	11,48	12.71	12.29	12.71	12.30	12.71	42.71	12.30	12.71	12.31	12.70	149.63
Task Lights	-	-				4	4.			4		-	-
Area Lights	7.95	7.23	8.00	7.65	8.01	7.71	7.95	8.01	7.71	7.96	7.86	7.90	93.95
Total	46.50	41.43	45.84	44.35	50.06	56.15	74.33	71.24	49.36	44.66	#2.76	45.36	612.04


Space Heating


Gas Consumption (Btu x000,000)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	*		-		-	-		5	-	-	-
Heat Reject.	τ	-	8	-			8	8	-	31		-	-
Refrigeration						175		-	-		1.1	-	-
Space Heat	385.3	251.9	160.2	96.8	21.1	5.5	3		14.5	89.1	222.7	372.E	1,619.6
HP Supp.		-	4	1	1	10	1	-		100		-	-
Hot Water	-	-	8	-		1.1		-	1	3		-	2
Vent, Fans	-	-				-	-	-	-			-	-
Pumps & Aux.		-	-	1	4	-		~		8	-	~	-
Ext. Usage	-	-	-	-		-		-		-		-	-
Misc. Equip.	τ.		8					-		-			
Task Lights	-			-				-	-	-	-		
Area Lights	-	-		20	-	-	~	-		-	-	-	-
Total	385.3	251.9	160.2	96.8	21.1	5.5	~	-	14.5	89.1	222.7	372.6	1,619,6

Project/Run: Pierpont Plaza - Window Glass Type EEM_3







-----Area Lighting Exterior Usage Task Lighting Pumps & Aux. Misc. Equipment Ventilation Fans

Ht Pump Supp. Space Heating

Water Heating

Refrigeration Heat Rejection Space Cooling

Electric Consumption (kWh x000)

	Jan	Feb	Mar	Apr	May	Jun	Jui	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	0.07	0.33	0.37	0.75	5.66	11.14	23.04	19.90	6.52	2.08	0.31	0.01	70.18
Heat Reject.	T	-		-		-	-	-	T			-	-
Refrigeration				-				1-		100			-
Space Heat		-	+	4	÷		÷.	-	1.0			-	
HP Supp.	-	-			-	-	1.1	-	-		-	-	-
Hot Water	10.60	10.05	11.23	10.68	9.80	8,37	7.69	7.08	6.79	7.54	8.04	9.70	107.57
Vent. Fans	5.23	4.76	5.27	5.05	5.90	6.16	7.15	6.90	5.69	5.39	5.20	5,19	67.90
Pumps & Aux.	0.11	0.09	0.08	0.06	0.02	0.01	-	-	0.02	0.05	0.09	0.11	0.64
Ext. Usage	8.35	6.60	7.31	7.07	5.41	5.24	5.41	8.00	7.74	8.00	8.08	8.35	85.55
Misc. Equip.	12.71	11.48	12.71	12.29	12.71	12.30	12.71	12.71	12.30	12.71	12.35	12.70	149.63
Task Lights	. 59	1	-	-		2	-	-	1.4	~	-	-	-
Area Lights	7.95	7.23	8.00	7.66	8.01	7.71	7.95	5.01	7.71	7.96	7.86	7.90	93.95
Total	45.01	40.53	44.96	43.55	47.52	50.92	63.95	62.60	45.75	43.73	41.89	43.97	575.40

Gas Consumption (Btu x000,000) Jan Jui Oct Ech Sep Dec Total Space Cool Heat Reject. Refrigeratio 0.66 176.67 Space Heat 180.85 99.97 50.18 24.34 0.44 0.05 22.45 82.59 638.66 HP Supp. Hot Water Vent. Fans Pumps & Aux. Ext. Usage Misc. Equip. Task Lights Area Liphts Total 180.85 99.93 50.18 24.34 0.94 0.05 0.66 22.46 82.59 175.57 538.65

eQUEST 3.65.7158

MICHAEL BLACK

Pierpont Plaza Place

